

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0410:151 Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Hochiki America, 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268
Contact: *Bob Misiuk (714) 670-3251

DESIGN: Models DCD-135 and DCD-190, fixed temperature and rate of rise heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Temperature: DCD-135: 135 °F
DCD-190: 190 °F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as fixed temperature and rate of rise heat detector for use listed bases (CSFM Listing No. 7300-0410:132) and separately listed fire alarm control units.

*Rev. 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager